



NOTES:

1. ADDITIONAL REINFORCEMENTS SHALL BE SPECIFIED BY THE ENGINEER.
2. MINIMUM COMPRESSIVE STRENGTH FOR CONCRETE SHALL BE 3000 PSI.
3. BEDDING, BACKFILL AND COMPACTION SHALL BE SPECIFIED IN THE STANDARD DRAWING.
4. ALL FORM BOARDS SHALL BE REMOVED PRIOR TO BACKFILLING.
5. NO ALLOWANCE SHALL BE MADE FOR FRICTION BETWEEN THE PIPE WALL.
6. DESIGN PRESSURE: 150 PSI.

SCHEDULE OF DIMENSIONS AND MATERIALS

| PIPE SIZE (INCHES) | DIMENSIONS (FT.) | | | | TIE RODS REQ'D | |
|--------------------|------------------|-----|-----|---|----------------|-----|
| | A | B | C | D | DIA. | NO. |
| 6 | 2.0 | 2.0 | 1.0 | | 3/4 | 2 |
| 8 | 2.5 | 2.5 | 1.0 | | 3/4 | 2 |
| 10 | 3.5 | 3.0 | 1.0 | | 3/4 | 2 |
| 12 | 5.0 | 3.0 | 1.0 | | 3/4 | 2 |
| 16 | 6.0 | 4.0 | 1.5 | | 3/4 | 4 |
| 20 | 8.0 | 5.0 | 1.5 | | 3/4 | 6 |
| 24 | 9.0 | 6.0 | 1.5 | | 3/4 | 8 |

NOTE: THRUST COLLAR AREAS TO BE COMPUTED ON BASIS OF 2000 LBS/SF SOIL RESTRAINT BEARING.



STANDARD CONSTRUCTION DETAIL
WATER MAIN THRUST COLLAR

NTS

INDEX

RW-13

DEC 2015